



**INVITATION TO BID - SMALL PUBLIC WORKS ROSTER
NAKATA POOL FIBERGLASS #2024-02
ADDENDUM A**

Bainbridge Island
Metropolitan Park and Recreation District
11700 Meadowmeer Circle NE
Bainbridge Island, WA 98110

Project Manager: Mike Omans, michaelo@biparks.org, (206) 565-5675

Procurement Manager: Michelle Miller, michellem@biparks.org

Date Prepared: April 25th, 2024

General Description: Clarifications/Questions During Mandatory Pre-Bid Walkthrough
Replace Original Bidder Proposal Form with Attached Bidder Proposal Form to add Additive Option A for Hot Tub to be an optional addition to Scope of Work

The following modifications are hereby made part of the contract documents:

DOCUMENTS

1. Bidder's Proposal Form (includes Additive Option A: Hot Tub) – Three (3) Total Pages
2. Questions & Answers
3. Swirl Pool Section (Hot Tub Plans)

BIDDER'S PROPOSAL FORM Page 1 of 3

NAKATA POOL FIBERGLASS #2024-02

On Bainbridge Island in Kitsap County, WA, and has read and thoroughly understands the plans, specifications, and contract governing the work included in this improvement, and the method by which payment will be made for said work, and hereby propose to undertake and compete the work included in this improvement in accordance with the said plans, specifications, and contract and at the following schedule of rates and prices.

NOTE: Unit prices and total prices for all items, all extensions, and total amount of bid must be shown.

Show prices and legible figures (not words) written in ink or typed

ITEM No.	BID ITEM DESCRIPTION	UNIT OF MEASURE	QTY	SUM TOTAL
1	Base Bid Amount	Lump Sum	1	
2	Mobilization and Demobilization	Lump Sum	1	

BID TOTAL \$ _____

WASHINGTON STATE SALES TAX (9.2%) \$ _____

GRAND TOTAL BID \$ _____

ADDITIVE A: COST FOR ADDING HOT TUB TO SCOPE OF WORK

ITEM No.	ADDITIVE A ITEM DESCRIPTION	UNIT OF MEASURE	QTY	SUM TOTAL
A	<i>Base Bid Amount – Hot Tub Additional Cost</i>	<i>Lump Sum</i>	<i>1</i>	

ADDITIVE A TOTAL \$ _____

WASHINGTON STATE SALES TAX (9.2%) \$ _____

ADDITIVE A TOTAL BID \$ _____
BIDDER'S PROPOSAL FORM Page 2 of 3
NAKATA POOL FIBERGLASS #2024-02

Evaluation of Bids: The evaluation of bids and determination of the lowest responsive and responsible bid will be based on Base Bid Subtotal in the above table.

Addenda: Bidder acknowledges review of all Addenda through No. _____

Responsible Bidder Information: Providing the following information is MANDATORY in order to meet "Responsible Bidder" requirements. Failure to provide this information may disqualify your bid as being "non-responsive". *If your business is not required to have one of the following numbers, provide an explanation.*

- State of Washington Contractor Registration No. _____
- State of Washington Unified Business Identifier No. _____
- Employment Security Department No. _____
- State Excise Tax Registration No. _____

- Have you received training, provided by the Department of Labor and Industries or by a provider whose curriculum has been approved by L&I, on the requirements related to public works and prevailing wages? If no, have you completed three or more public works projects *and* maintained a valid business license in Washington in the past three years?
 - Yes
 - No (If no, you are not eligible to bid on this project)
 - No Account – Explain Why:

- Is the payment of Worker's Comp (Industrial Insurance) Premiums current? If your business does not have a Worker's Comp account with the WA State Dept of Labor & Industries, please explain why:
 - Yes
 - No (If no, you are not eligible to bid on this project)
 - No Account – Explain Why:

- Are you disqualified from bidding on public works projects in the State of Washington?
 - Yes (If yes, you are not eligible to bid on this project)
 - No

Contractor's Signature

Date

BIDDER'S PROPOSAL FORM Page 3 of 3
NAKATA POOL FIBERGLASS #2024-02

SUBMITTED BY:

Contractor's Name

Firm Name

Title

Address (Street/PO Box)

City State Zip

()
Telephone Number

Email

END, BIDDER'S PROPOSAL FORM
NAKATA POOL FIBERGLASS #2024-02

APRIL 22, 2024 10:00 AM PT WALKTHROUGH

QUESTIONS & ANSWERS

NAKATA POOL FIBERGLASS #2024-02

Q: You are only draining the pool in August?

A: Yes, Due to a high-water table we can only fully drain the pool in the late summer.

Q: Was there traction sand applied to stairs and would you want that traction re-applied?

A: Yes, there was traction sand applied and we would like it re-applied to the stairs, ladders, lazy river, ADA ramp, and beach area.

Q: Will you be able to shut down HVAC during sand blasting?

A: Yes, we can shut off the natatorium HVAC during blasting.

END, APRIL 22, 2024 10:00 AM PT WALKTHROUGH

QUESTIONS & ANSWERS

NAKATA POOL FIBERGLASS #2024-02